PRODUCT CERTIFICATE

CERTIFICATE NO.: CQC20190103012252 99

NAME AND ADDRESS OF THE APPLICANT

Zhejiang Zhegui Electric Power Equipment Co., Ltd

Room 101, Building 1 and 2, Donggangjiayuan, Dongyangtian Village, Beibaixiang Town, Yueqing City, Wenzhou City, Zhejiang Province

NAME AND ADDRESS OF THE MANUFACTURER

Zhejiang Zhegui Electric Power Equipment Co., Ltd

Room 101, Building 1 and 2, Donggangjiayuan, Dongyangtian Village, Beibaixiang Town, Yueqing City, Wenzhou City, Zhejiang Province

NAME AND ADDRESS OF THE FACTORY

Zhejiang Zhegui Electric Power Equipment Co., Ltd (V053459)

1/F,Building 1 , Donggangjiayuan, Dongyangtian Village, Beibaixiang Town, Yueqing City, Wenzhou City, Zhejiang Province

PRODUCT NAME, MODEL AND SPECIFICATION

Distribution Boards

XM InA=250A～10A,Icw=6kA;Ue=400V、230V,Ui=400V;50Hz;IP30-操作面 IP20C;户内型

THE STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS

GB/T 7251.3-2017

TYPE OF CERTIFICATION SCHEMES

Type testing+Follow up factory inspection

This is to certify that the above mentioned product(s) complies with the requirements of certification rules of CQC11-462176-2018 .

Valid from: Aug.14,2020 **Valid until:** Sep.03,2024

The validity of the certificate is subject to positive result of the regular follow up inspection by issuing certification body until the expiry date.

Accredited by China National Accreditation Service for Conformity Assessment CNAS C001-P

President: _____

Lu Mei

CHINA QUALITY CERTIFICATION CENTRE 中国质量认证中心

CHINA QUALITY CERTIFICATION CENTRE

Section 9,No.188,Nansihuan Xilu, Beijing 100070 P.R.China

http://www.cqc.com.cn

C 0343480